

Worldwide Contacts www.tyco-fire.com

## **DV-5**<sup>A</sup> Automatic Water Control Valve, Single Interlock Preaction, Electric Actuation, Fire Protection Systems 1 1/2 to 8 Inch (DN40 to DN200)

### IMPORTANT

Refer to Technical Data Sheet TFP2300 for warnings pertaining to regulatory and health information.

Always refer to Technical Data Sheet TFP700 for the "INSTALLER WARNING" that provides cautions with respect to handling and installation of sprinkler systems and components. Improper handling and installation can permanently damage a sprinkler system or its components and cause the sprinkler to fail to operate in a fire situation or cause it to operate prematurely.

Scan the QR code or enter the URL in a web browser to access the most up-to-date electronic version of this document. Data rates may apply.



## General Description

The TYCO DV-5A Automatic Water Control Valve Single Interlock Preaction Electric Actuation is a diaphragm type valve that can be used in single interlock preaction fire protection systems. When properly trimmed, the double seat design of the DV-5A Valve also provides actuation of fire alarms upon system operation.

The diaphragm style design of the DV-5A Valve allows external resetting, providing for easy resetting of a deluge system without having to open a valve handhole cover to manually reposition



Available End Connections and Weights — Ib (kg)									
End Cor	nection	ection Nominal Valve Size ANSI Inches (DN)							
Inlet	Outlet	1 1/2 (40)	2 (50)	3 (80)	4 (100)	6 (150)	165,1 mm	8 (200)	
Thread	Thread	26 (11,8)	25 (11,3)	N/A	N/A	N/A	N/A	N/A	
Groove	Groove	25 (11,3)	25 (11,3)	60 (27,2)	95 (43,1)	177 (80,3)	177 (80,3)	327 (148,3)	
Flange	Groove	N/A	N/A	66 (30,0)	106 (48,1)	190 (86,2)	N/A	346 (157,0)	
Flange	Flange	N/A	N/A	72 (32,7)	116 (52,6)	204 (92,5)	N/A	365 (165,6)	

a clapper and/or latch mechanism. Simply re-pressurizing the diaphragm chamber resets the valve.

The DV-5A features internal and external coating of the valve to provide corrosion resistance. The external corrosion resistance of the epoxy coating permits the use of the DV-5A in corrosive atmospheres associated with many types of industrial processing plants and outdoor installations.


The DV-5<sub>A</sub> Single Interlock Preaction Electric Actuation Valve is offered with or without a System Main Control Valve. The DV-5<sub>A</sub> Single Interlock Preaction Electric Actuation Valve utilizes automatic sprinklers and a supplemental detection system, comprised of electric detection comprised of heat detectors, smoke detectors, and manual pull stations. Actuation of the detection system automatically operates (releases) the DV-5<sub>A</sub> Valve, allowing water to flow into the sprinkler piping system and to be discharged from any sprinklers that may subsequently open.

## **TFP1421** Page 2 of 18

			Nominal Valve Size ANSI Inch (DN)								
Item	Description	Qty.	1 1/2 (DN40)	2 (DN50)	3 (DN80)	4 (DN100)	6 (DN150)°	8 (DN200)			
			P/N	P/N	P/N	P/N	P/N	P/N			
1	Valve Body	1	N/R	N/R	N/R	N/R	N/R	N/R			
2	Diaphragm	1	545000020	545000020	545000030	545000040	545000060	545000080			
3	Diaphragm Cover	1	N/R	N/R	N/R	N/R	N/R	N/R			
4	Hex Bolt, Short	2ª	545100001	545100001	545100002	545100003	545100004	545100003			
5	Hex Bolt, Long	2	545100011	545100011	545100012	545100013	545100014	545100015			
6	Lift Washer	2 <sup>b</sup>	N/A	N/A	545100021	545100022	545100023	545100022			
7	Hex Nut	2	545100031	545100031	545100032	545100033	545100034	545100033			
8	Hoist Ring	2	545100041	545100041	545100041	545100041	545100041	545100041			
9	Flat Washer	2	N/A	N/A	545100024	545100025	545100026	545100025			

#### NOTES

d. Order replacements parts only via Part Numbers given, do not replace Hex Bolt, Hex Nut, Lift Washer or Hoist Ring with common hardware parts.
e. Also applicable to metric 165,1 mm size.





[			Flange Drilling Specification											Dim. A
	Nominal Valve Nominal Dimensions in Inches and (mm)										Bolt Circle Diameter			
	Size ANSI Inches (DN)		6l B16.1 Iss 125			7005-2 N16)⁵	2		B 2210 10K)			5 2129 able E)		Dim. B
	(BN)	Α	в	N	Α	в	N	Α	В	Ν	Α	в	Ν	B B Diameter
	3 (80)	6.00 (152,4)	0.75 (19,0)	4	6.30 (160,0)	0.75 (19,0)	8	5.90 (150,0)	0.59 (15,0)	8	5.75 (146,0)	0.71 (18,0)	4	Qty. N Number of
	4 (100)	7.50 (190,5)	0.75 (19,0)	8	7.09 (180,0)	0.75 (19,0)	8	6.89 (175,0)	0.60 (15,0)	8	7.00 178,0)	0.71 (18,0)	8	Bolt Holes
	6 (150)	9.50 (241,3)	0.88 (22,2)	8	9.45 (240,0)	0.91 (23,0)	8	9.45 (240,0)	0.75 (19,0)	8	9.25 (235)	0.87 (22,0)	8	a. Same drilling as for ANSI B16.5 (Class 150) and ANSI B16.42 (Class 150) b. Same drilling as for
	8 (200)	11.75 (298,5)	0.88 (22,2)	8	11.61 (295,0)	0.91 (23,0)	12	11.42 (290,0)	0.75 (19,0)	12	11.50 (292,0)	0.87 (22,0)	8	BS 4504 Section 3.2 (PN16) and DIN 2532 (PN16)
-						FLANG	θE	T/ DRILLI	ABLE /	-		TIONS		

## TFP1421 Page 3 of 18

Port	Port Description	Port Sizes, NPT Inch per ANSI B1.20.1									
Port	Port Description	1 1/2 (DN40)	2 (DN50)	3 (DN80)	4 (DN100)	6 (DN150)ª	8 (DN200)				
P1	Diaphragm Chamber Supply	1/2	1/2	1/2	1/2	1/2	1/2				
P2	Water Supply Pressure & Alarm Test	1/2	1/2	1/2	1/2	1/2	1/2				
P3	Alarm Actuation	3/4	3/4	3/4	3/4	3/4	3/4				
P4	Automatic Drain Valve	1/2	1/2	1/2	1/2	1/2	1/2				
P5	System Drain	3/4	3/4	3/4	3/4	3/4	3/4				
P6	Main Drain	3/4	3/4	1 1/4	2	2	2				
P7	System Air Supply	1/2	1/2	1/2	1/2	1/2	1/2				







Typically, the system designer selects the detection components for a single interlock preaction system that will respond to a fire sooner than the automatic sprinklers. Consequently, the system will experience a minimal delay in water delivery over that for a wet pipe sprinkler system because the system will have essentially filled with water before a sprinkler operates. The DV-5A Single Interlock Preaction Electric Actuation Valve automatically supervises the integrity of the overall system. Supervision is provided by monitoring a relatively low air pressure in the system via a low pressure alarm switch so as to detect leaks in the system that otherwise would result in unwanted water discharge should the system operate in a fire condition.

Supervised single interlock preaction systems are generally used to protect areas where there is danger of serious water damage that might result from damaged automatic sprinklers or piping. Typically, such areas include computer rooms, storage areas for valuable artifacts, libraries, and archives.

Single interlock preaction systems are also effectively used to protect properties where a pre-alarm of a possible fire condition may allow time for fire extinguishment by alternate suppression means, prior to a sprinkler discharge. In the event the fire cannot otherwise be extinguished, the preaction sprinkler system will then perform as the primary fire protection system.

## NOTICE

The DV-5<sub>A</sub> Single Interlock Preaction Electric Actuation Valve described herein must be installed and maintained in compliance with this document, as well as with the applicable standards of the NATIONAL FIRE PRO-TECTION ASSOCIATION (NFPA), in addition to the standards of any other authorities having jurisdiction. Failure to do so may impair the performance of these devices.

The owner is responsible for maintaining their fire protection system and devices in proper operating condition. Contact the installing contractor or product manufacturer with any questions.

# Technical Data

Approvals UL and C-UL Listed FM Approved

Listing and Approvals are based on DV-5a Single Interlock Preaction Electric Actuation Valve being trimmed as described in Figure 5.

### DV-5A Valve

Components for the 1 1/2 in. to 8 in. (DN40 to DN200) DV-5A Valve are shown in Figure 1. The DV-5A Valve is for vertical installations. It is rated for use at service pressures of 20 to 300 psi (1,4 to 20,7 bar).

The take-out dimensions are shown in Figure 3, and flanged connections are available drilled per ANSI, ISO, AS, and JIS specifications (see Table A). Threaded inlet and outlet connections are available in NPT or ISO 7-1. Threaded port connections are NPT threaded.

*Note:* PN16 flanges are pressure rated to 16 bar.

### Valve Trim

The maximum pressure rating for the Single Interlock Preaction Electric Actuation is dependent on the separately ordered solenoid valve per Technical Data Sheet TFP2180.

When the system pressure is greater than 175 psi (12,1 bar), provision is to be made to replace the standard order 300 psi (20,7 bar) Water Pressure Gauges with separately ordered 600 psi (41,4 bar) Water Pressure Gauges.

If the addition of an Alarm Control Valve is desired or required by the local AHJ, the Alarm Control Valve noted as Item H in Figure 8 is to be a separately ordered electronically supervised normally open valve.

External trim connections are NPT threaded. EMEA trim is provided with NPT x ISO 7-1 thread adapters.


Pressure Loss

See Graph A

## Detection System

See the Electric Actuation subsection

System Air Pressure Requirements The supervisory air (nitrogen) pressure is to be  $10 \pm 2$  psi (0,69  $\pm$ 0,07 bar). The use of a higher supervisory pressure is subject to approval by the authority having jurisdiction, and it should be understood that the use of a higher supervisory pressure may increase water delivery time. The use of a lower



supervisory pressure may prevent clearing the alarm of the Supervisory Low Pressure Switch (Item T - Figure 8), which is factory set to alarm at  $5 \pm 1$ psi (0,34  $\pm$  0,07 bar) on decreasing pressure. The supervisory air supply pressure of 10  $\pm 2$  psi (0,69  $\pm$  0,07 bar) can be provided by any of the following methods. Refer to the applicable data sheet for laboratory approval information.

- Model G16AC812 (self contained) Automatic Supervisory Air Supply described in Technical Data Sheet TFP1620.
- A maximum 200 psi (13,8 bar) plant air supply in combination with the Model AMD-1 Air Maintenance Device described in Technical Data Sheet TFP1221.
- A maximum 3000 psi (206,9 bar) nitrogen cylinder in combination with the Model AMD-3 Nitrogen Maintenance Device described in Technical Data Sheet TFP1241.

**Note:** The dew point of the air or nitrogen supply for a system exposed to freezing conditions must be maintained below the lowest ambient temperature to which the system piping will be exposed. Introduction of moisture into the system piping can create ice build-up that could prevent proper operation of the system.

The Supervisory Low Pressure Switch (Item T - Figure 8) is factory set at  $5 \pm 1$  psi (0,34  $\pm$  0,07 bar) on decreasing pressure. The Pressure Relief Valve (Item S - Figure 8) is factory set to fully open at 25  $\pm$  2 psi (1,72  $\pm$  0,14 bar) and it begins to crack open at a pressure of about 18 psi (1,24 bar).

## Materials of Construction

#### Valve Body

Epoxy coated ductile iron per ASTM A536-77, Grade 65-45-12

#### **Diaphragm Cover**

Epoxy coated ductile iron per ASTM A536-77, Grade 65-45-12

#### Diaphragm


Polyester fabric reinforced, TEFLON coated, EPDM rubber per ASTM D2000

Diaphragm Cover Fasteners Aluminum zinc coated steel

#### **Common Hardware Trim**

- Common hardware pipe fittings are galvanized or black as required and are malleable per ASME B16.3.
- Common hardware pipe nipples are galvanized or black as required and are Schedule 40 per ASTM A53 or A135.
- Common hardware compression fittings are brass per ASTM B16.
- Common hardware tubing is Type L copper per ASTM B88.

**TFP1421** Page 6 of 18



## **Operation**

The TYCO DV-5A Valve is a diaphragm style valve that depends upon water pressure in the Diaphragm Chamber (see Figure 2A) to hold the Diaphragm closed against the water supply pressure.

When the DV-5A Valve is set for service, the Diaphragm Chamber is pressurized through the trim connections from the inlet side of the system's main control valve.

Opening the Electric Actuation Trim trips the Model MRA-1 Manual Reset Actuator. Tripping the MRA-1 releases water from the DV-5A Diaphragm Chamber faster than it can be replenished through a 1/8 in. (3,2 mm) restriction located in the Diaphragm Chamber Supply Connection. Release of water through the MRA-1 results in a rapid pressure drop in the DV-5A Diaphragm Chamber. The force differential applied through the Diaphragm to hold the Diaphragm in the set position is then reduced below the valve trip point. The water supply pressure then forces the Diaphragm open permitting water to flow into the system piping, as well as through the Alarm Port to actuate the system alarms (see Figure 2B).

Upon opening of the DV-5A Valve, the Model MRA-1 Manual Reset Actuator opens to constantly vent the DV-5A Diaphragm Chamber to hydraulically latch the DV-5A in the tripped position until manually reset.

In standby mode, the integrity of the system piping is supervised by a low pressure alarm switch.

See the Electric Actuation section for additional information.

## Electric Actuation

The Electric Actuation Trim forms a part of the laboratory approval of the DV-5A Valves and is necessary for their proper operation.

The Electric Actuation Trim is required for electric operation of the DV-5A Valve by a detection system consisting of electrical devices such as heat sensitive thermostats, smoke detectors, and/or electric manual pull stations as shown in Figure 4.

**Note:** For Single Interlock Preaction Systems with Electric Actuation, the system designer typically selects electric detection devices that will operate sooner than the automatic sprinklers chosen for use on the sprinkler piping.

Dimensions are provided in Figure 7.

#### Notes:

The normally closed, de-energized, Solenoid Valve is separately ordered and selected based on the required laboratory approval acceptable to the authority having jurisdiction. Refer to Technical Data Sheet TFP2180 for specific laboratory approvals.

Consult with the applicable standards of the Approval agency regarding installation criteria pertaining to electric actuation circuitry.

Due to the functionality of the Model MRA-1 Manual Reset Actuator, the release circuit of the releasing panel need only provide the typical ten minutes of alarm condition intended to energize the Solenoid Valve to open. After the ten minute duration, at which point should the Solenoid Valve become de-energized and close (especially while operating under battery back-up), the MRA-1 will have already automatically opened, thereby preventing the DV-5A Diaphragm Chamber from becoming re-pressurized, and preventing an inadvertent closing of the DV-5A during a fire event.

# Installation

The TYCO DV-5A Single Interlock Preaction Electric Actuation Trim Valve is to be installed in accordance with this section.

## NOTICE

DV-5A Automatic Water Control Valves are designed to be used in freshwater systems. When the supply is from an alternative source such as brackish water, saltwater, or contains additives such as foam, the limited warranty is reduced to one year from the time of installation. An increase in frequency of inspections is required when the valve is exposed to such supplies and other corrosive conditions or chemicals that could impact valve materials or the operation of the assembly. The system and all components must be designed accordingly for the increased demand. It is required to thoroughly flush the valve and trim assembly with freshwater and reset to the set condition after each operation.

Proper operation of the DV-5A Single Interlock Preaction Electric Actuation Valve depends upon their trim being installed in accordance with the instructions given in this technical data sheet. Failure to follow the appropriate trim diagram may prevent the DV-5A Valve from functioning properly, as well as void approvals and the manufacturer's warranties.

The DV-5<sub>A</sub> Valve must be installed in a readily visible and accessible location.

The DV-5<sub>A</sub> Valve and associated trim must be maintained at a minimum temperature of  $40^{\circ}$ F ( $4^{\circ}$ C).

Heat tracing of the DV-5A Valve or its associated trim is not permitted. Heat tracing can result in the formation of hardened mineral deposits that are capable of preventing proper operation.

Always open the system control valves slowly to avoid a sudden rush of water entering the system. The DV-5A Valve is to be installed in accordance with the following criteria:

**Step 1.** All nipples, fittings, and devices must be clean and free of scale and burrs before installation. Use pipe thread sealant sparingly on male pipe threads only.

**Step 2.** The DV-5A Single Interlock Preaction Electric Actuation Valve must be trimmed in accordance with the trim illustration shown in Figure 5.

**Note:** If the addition of an Alarm Control Valve is desired or required by the local AHJ, the Alarm Control Valve noted as Item H in Figure 8 is to be a separately ordered electronically supervised normally open valve.

**Step 3.** Care must be taken to ensure that check valves, strainers, globe valves, etc. are installed with the flow arrows in the proper direction.

**Step 4.** Drain tubing to the Drip Funnel must be installed with smooth bends that will not restrict flow.

**Step 5.** The Main Drain and Drip Funnel Drain may be interconnected provided a check valve is located at least 12 in. (300 mm) below the Drip Funnel.

**Step 6.** Suitable provision must be made for disposal of drain water. Drainage water must be directed such that it will not cause accidental damage to property or danger to persons.

**Step 7.** Connect the Diaphragm Supply Valve to the inlet side of the System Main Control Valve in order to facilitate setting of the DV-5A Valve (see Figure 8).

**Step 8.** Unused Pressure Alarm Switch connections must be plugged.


**Step 9.** A suitable automatic supervisory air (nitrogen) supply, as described in the Technical Data section, is to be installed in accordance with the applicable technical data sheet and set for  $10 \pm 2$  psi (0,69  $\pm$  0,14 bar).

**Step 10.** A desiccant dryer, when required for the supervisory air supply, is to be installed between a drip leg and the Model AMD-1 Air Maintenance Device or between the Model G16AC812 Automatic Supervisory Air Supply and the Preaction Trim.

**Step 11.** The Supervisory Low Pressure Switch is to be wired to the supervisory alarm initiating circuit of an alarm panel.


**Step 12.** Conduit and electrical connections are to be made in accordance with the applicable standards of the approval agency.

**Step 13.** Before a system hydrostatic test is performed, the DV-5<sub>A</sub> Diaphragm Chamber is to be depressurized, the Automatic Drain Valve is to be temporarily replaced with a plug, and the Diaphragm Cover Bolts must be uniformly and securely tightened using a cross-draw sequence. After tightening, double-check to make certain that all of the Diaphragm Cover Bolts are securely tightened. See Table B in the Care and Maintenance section for torque specifications.



### DV-5A VALVES WITH SINGLE INTERLOCK PREACTION ELECTRIC ACTUATION TRIM SEMI-ASSEMBLED

### **TFP1421** Page 9 of 18



## **TFP1421** Page 10 of 18


ITEM	QTY	DESCRIPTION	СН	1 1/2 IN. (DN40)	2 IN. (DN50)	3 IN. (DN80)	4 IN. (DN100)	6 IN. (DN150)⁵	8 IN. (DN200)
23	1	PIPE PLUG	1	3/4"	3/4"	3/4"	3/4"	3/4"	3/4"
24	2	UNION		1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
25	1	STREET ELBOW		1/4" x 90°	1/4" x 90°	1/4" x 90°	1/4" x 90°	1/4" x 90°	1/4" x 90°
26	1	ELBOW		1/2" x 45°	1/2" x 45°	1/2" x 45°	1/2" x 45°	1/2" x 45°	1/2" x 45°
27	4	ELBOW	1	1/2" x 90°	1/2" x 90°	1/2" x 90°	1/2" x 90°	1/2" x 90°	1/2" x 90°
28	1	CROSS	<b>↓</b>	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
29	2	TEE		1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
30	1	REDUCING TEE	1	1/2" x 1/4" x 1/2"	1/2" x 1/4" x 1/2"	1/2" x 1/4" x 1/2"	1/2" x 1/4" x 1/2"	1/2" x 1/4" x 1/2"	1/2" x 1/4" x 1/2"
31	2	REDUCING TEE		1/2" x 1/2" x 1/4"	1/2" x 1/2" x 1/4"	1/2" x 1/2" x 1/4"	1/2" x 1/2" x 1/4"	1/2" x 1/2" x 1/4"	1/2" x 1/2" x 1/4"
32	2	REDUCING TEE	1	3/4" x 1/2" x 3/4"	3/4" x 1/2" x 3/4"	3/4" x 1/2" x 3/4"	3/4" x 1/2" x 3/4"	3/4" x 1/2" x 3/4"	3/4" x 1/2" x 3/4"
33	1	REDUCING TEE		3/4" x 3/4" x 3/4"	3/4" x 3/4" x 3/4"	1 1/4" x 1 1/4" x 3/4"	2" x 2" x 3/4"	2" x 2" x 3/4"	2" x 2" x 3/4"
34	1	PIPE NIPPLE	1	1/4" x CLOSE	1/4" x CLOSE	1/4" x CLOSE	1/4" x CLOSE	1/4" x CLOSE	1/4" x CLOSE
35	1	PIPE NIPPLE		1/4" x 1 1/2"	1/4" x 1 1/2"	1/4" x 1 1/2"	1/4" x 1 1/2"	1/4" x 1 1/2"	1/4" x 1 1/2"
36	4	PIPE NIPPLE		1/2" x CLOSE	1/2" x CLOSE	1/2" x CLOSE	1/2" x CLOSE	1/2" x CLOSE	1/2" x CLOSE
37	4	PIPE NIPPLE	1	1/2" x 1 1/2"	1/2" x 1 1/2"	1/2" x 1 1/2"	1/2" x 1 1/2"	1/2" x 1 1/2"	1/2" x 1 1/2"
38	1	PIPE NIPPLE		1/2" x 2"	1/2" x 2"	1/2" x 2"	1/2" x 2"	1/2" x 2"	1/2" x 2"
39	2	PIPE NIPPLE	1	1/2" x 2 1/2"	1/2" x 2 1/2"	1/2" x 2 1/2"	1/2" x 2 1/2"	1/2" x 2 1/2"	1/2" x 2 1/2"
40	1	PIPE NIPPLE		1/2" x 4 1/2"	1/2" x 4 1/2"	1/2" x 4 1/2"	1/2" x 4 1/2"	1/2" x 4 1/2"	1/2" x 4 1/2"
41	1	PIPE NIPPLE	$\overline{\checkmark}$	1/2" x 5"	1/2" x 5"	1/2" x 5"	1/2" x 5"	1/2" x 5"	1/2" x 5"
42	1	PIPE NIPPLE	1	1/2" x 8 1/2"	1/2" x 8 1/2"	1/2" x 8 1/2"	1/2" x 8 1/2"	1/2" x 8 1/2"	1/2" x 8 1/2"
43	1	PIPE NIPPLE	$\overline{\checkmark}$	3/4" x 1 1/2"	3/4" x 1 1/2"	3/4" x 1 1/2"	3/4" x 1 1/2"	3/4" x 1 1/2"	3/4" x 1 1/2"
44	1	PIPE NIPPLE	17	3/4" x 4 1/2"	3/4" x 4 1/2"	3/4" x 4 1/2"	3/4" x 4 1/2"	3/4" x 4 1/2"	3/4" x 4 1/2"
45	1	TUBING, MRA-1 DRAIN	l ·	545100065	545100065	545100066	535002140	535002160	535002180
46	1	TUBING, MC-2 DRAIN		535000220	535000220	535000230	535000240	535000260	535000280
47	1	TUBING, SOLENOID DRAIN		535001020	535001020	535000630	535000640	535000660	535000680
48	1	TUBING ASSY, ALARM TEST INTERCONNECT		535000320	535000320	535000330	535000340	535000360	535000380
49	1	TUBING ASSY, SYSTEM DRAIN		535000420	535000420	535000430	535000440	535000460	535000480
50	1	PIPE NIPPLE		1/2" x 3 1/2"	1/2" x 3 1/2"	1/2" x 4 1/2"	1/2" x 5 1/2"	1/2" x 5 1/2"	1/2" x 6 3/4"
51	1	PIPE NIPPLE	17	1/2" x 5"	1/2" x 5"	1/2" x 5 1/2"	1/2" x 5 1/2"	1/2" x 5 1/2"	1/2" x 6 1/2"
52	1	PIPE NIPPLE		1/2" x 5"	1/2" x 5"	1/2" x 4 1/2"	1/2" x 5"	1/2" x 7 1/2"	1/2" x 9 1/2"
53	1	PIPE NIPPLE	$\overline{}$	3/4" x 5"	3/4" x 5"	3/4" x 6"	3/4" x 7"	3/4" x 9"	3/4" x 11 1/2"
54	1	PIPE NIPPLE	1	3/4" x 4 1/2"	3/4" x 4 1/2"	1 1/4" x 3 1/4"	2" x 3"	2" x 3"	2" x 3"
55	1	PIPE NIPPLE	$\overline{}$	3/4" x 6 1/2"	3/4" x 6 1/2"	1 1/4" x 5 1/2"	2" x 5"	2" x 6"	2" x 8"
	2	WATER PRESSURE GAUGE, 300 PSI / 2000 kPa (AMER/APAC)		923431005	923431005	923431005	923431005	923431005	923431005
56	2	WATER PRESSURE GAUGE, 20 bar / 2000 kPa (EMEA)		025500013	025500013	025500013	025500013	025500013	025500013
57	1	AIR PRESSURE GAUGE, 80 PSI / 550 kPa RETARDED TO 250PSI / 1750 kPa		923431012	923431012	923431012	923431012	923431012	923431012
58	1	LABEL		545003005	545003005	545003005	545003005	545003005	545003005
59	1	LABEL WIRE		-	-	_	_	_	-
A1	1	DV-5A VALVE		SEE ORDERI	NG PROCEDURE,	SEPARATE DV-5/	VALVES WITHO	UT TRIM, FOR PA	RT NUMBERS
A2	2	WATERFLOW PRESSURE ALARM SWITCH, PS10-2 (AMER/APAC)		25710	25710	25710	25710	25710	25710
A2	2	WATERFLOW PRESSURE ALARM SWITCH, PS10-1 (EMEA)		0260	0260	0260	0260	0260	0260
A3	1	BUTTERFLY VALVE, G x G		51024A	51021A	_	_	_	_
АJ	1	BFV-300 BUTTERFLY VALVE, G x G		-	-	59300G030WS	59300G040WS	59300G060WS	59300G080WS
A.4	2	FIGURE 577 RIGID GROOVED COUPLING		57715ACP	57720ACP	—	—	—	—
A4	1	FIGURE 577 RIGID GROOVED COUPLING		-	—	57730ACP	57740ACP	57760ACP	57780ACP
A5	1	GROOVE x THREADED OUTLET WELDED TEE		545004000	545004001	_	_	-	_
A6	1	SOLENOID VALVE NORMALLY CLOSED				REFER TO	) TFP2180		
A7	1	INVERTED FLARE SHUT-OFF VALVE <sup>a</sup>		545100100	545100100	545100099	545100100	545100100	545100100
A8	1	FLARE FITTING 90° 1/2" NPT x 1/2" TUBE		545100062	545100062	545100062	545100062	545100062	545100062
A9	1	TUBING ASSY, DIAPHRAGM CHAMBER SUPPLY		540000015	540000020	540000030	540000040	540000060	540000080

NOTES a. Not VdS Approved. b. Also applicable to metric 165,1 mm size. CH - Common Hardware - See Materials of Construction section for specifications.

## FIGURE 6 (2 OF 2) DV-5A VALVES – SINGLE INTERLOCK PREACTION ELECTRIC ACTUATION TRIM EXPLODED VIEW

## **TFP1421** Page 11 of 18

Nominal Valve Size					Inches (mm)				
ANSI Inches (DN)	A	в	с	D	E	F	G	н	J
1 1/2	2.8	9.7	10.4	15.7	16.2	7.3	10.2	8.02	1.2
(40)	(71)	(246)	(264)	(399)	(411)	(185)	(259)	(204)	(31)
2	2.8	9.7	10.4	15.7	16.2	7.3	10.2	8.09	2.9
(50)	(71)	(246)	(264)	(399)	(411)	(185)	(259)	(205)	(74)
3	3.0	10.9	12.0	16.3	18.5	5.8	13.8	3.79	3.6
(80)	(76)	(277)	(305)	(414)	(470)	(147)	(351)	(96)	(91)
4	3.0	12.2	13.1	16.5	21.0	5.1	16.8	4.54	4.3
(100)	(76)	(310)	(333)	(419)	(533)	(130)	(427)	(115)	(109)
6 <sup>3</sup>	4.5	13.6	15.0	18.4	24.8	3.4	22.4	5.83	5.7
(150)	(114)	(345)	(381)	(467)	(630)	(86)	(569)	(148)	(145)
8	5.3	16.3	17.2	19.5	29.2	2.9	27.5	5.24	6.7
(200)	(135)	(414)	(437)	(495)	(742)	(74)	(699)	(133)	(170)



## Valve Setting Procedure

Perform Steps 1 through 16 when initially setting the TYCO DV-5A Electric Actuation Valve, after an operational test of the fire protection system, or after system operation due to a fire. See Figure 8.

**Step 1.** Close the System Main Control Valve (B).

**Step 2.** Close the Diaphragm Supply Valve (P).

**Step 3.** Close the Supervisory Air Supply Valve (S).

**Step 4.** Open the Main Drain Valve (D), System Drain Valve (E), and all auxiliary drains in the system. Close the auxiliary drain valves and the System Drain Valve (E) after water ceases to discharge. Leave the Main Drain Valve (D) open.

At this time make certain that the Pressure Gauge Valves and the Alarm Control Valve (H), as applicable, are open.

**Step 5.** Depress the plunger of the Automatic Drain Valve (F) to verify that it is open.

**Step 6.** Clean the Diaphragm Supply Strainer (Q) by removing the cleanout plug and strainer basket. The Diaphragm Supply Strainer (Q) may be flushed out by momentarily opening the Diaphragm Supply Valve (P).

**Step 7.** Replace any operated sprinklers on the system piping, as applicable.

**Step 8.** Reset the automatic actuation system. Reset the electric detection system in accordance with the manufacturer's instructions to de-energize the solenoid valve.

**Step 9.** Operate (open) the Manual Control Station (M) and then open the Diaphragm Supply Valve (P). After unaerated water ceases to discharge from the Manual Control Station (M) drain tube, slowly close the operating lever by pushing it up. Do not close the hinged cover at this time.

**Step 10.** After allowing water to flow out of the Manual Reset Actuator (N) drain tube until aerated water ceases to discharge, reset the Manual Reset Actuator (N) by pressing the Reset Knob and hold until water stops flowing from its drain tube and the pressure builds and reaches approximately 15 psi (1,0 bar) on the Diaphragm Gauge (K). Pressure will then build up in the DV-5<sub>A</sub> Diaphragm Chamber.

**Step 11.** Verify the ability for the DV-5<sub>A</sub> Diaphragm to hold pressure as follows:

- With the diaphragm chamber pressurized per Step 10, temporarily close the Diaphragm Supply Valve (P), and then observe the Diaphragm Gauge (K) for a drop in pressure.
- If a drop in pressure is noted, the DV-5A Diaphragm is to be replaced and/or any leaks must be corrected before proceeding to the next step.
- If the Diaphragm Gauge (K) indicates no drop in pressure, re-open the Diaphragm Supply Valve (P) and proceed to the next step.

**Step 12.** Open the Supervisory Air Supply Valve (S) to reestablish supervisory system air pressure at nominally 10 psi (0,68 bar).

**Step 13.** Partially open the System Main Control Valve (B). Slowly close the Main Drain Valve (D) as soon as water discharges from the Main Drain Valve (D). Observe the Automatic Drain Valve (F) for leaks. If there are leaks, determine/correct the cause of the leakage problem before proceeding.

## NOTICE


When the System Main Control Valve (B) is partially opened, the pressure on the DV-5A Diaphragm Chamber may increase. This increase in pressure is normal, and if the pressure is greater than 300 psi (20,7 bar), the pressure is to be relieved by partially and temporarily opening the Manual Control Station (M); however, do not allow the pressure as indicated on the Diaphragm Gauge (K) to drop below the supply pressure shown on the Water Supply Gauge (J), since this action may result in tripping of the DV-5A Valve.

**Step 14.** Close the hinged cover of the Manual Control Station (M) and insert a new break rod in the small hole through the top of the enclosing box.

**Step 15.** Fully open the System Main Control Valve (B).

**Step 16.** After setting a fire protection system, notify the proper authorities and advise those responsible for monitoring proprietary and/or central station alarms.

## TFP1421 Page 13 of 18



## **Care and Maintenance**

The following procedures and inspections must be performed as indicated, in addition to any specific requirements of the NFPA and any applicable standards recognized by the Approval agency. Any impairment must be immediately corrected. See Figure 8.

## NOTICE

If the water supply needs to be shut off to the DV-5<sub>A</sub> valve and trim and cannot be shut off upstream of the system, close the System Main Control Valve (B), the Diaphragm Supply Valve (P), and the Inverted Flare Shut-Off Valve (R). This will allow any trim above the System Main Control Valve (B) to be taken apart for service if necessary.

The frequency at which the following procedures and inspections are to be performed are to be in accordance with the NFPA and any applicable specific requirements of the standards recognized by the Approval agency.

Before closing a fire protection system main control valve for maintenance work on the fire protection system that it controls, permission to shut down the affected fire protection systems must first be obtained from the proper authorities and all personnel who may be affected by this action must be notified.

The owner is responsible for the inspection, testing, and maintenance of their fire protection system and devices in compliance with this document, as well as with the NFPA and any applicable standards recognized by the Approval agency. Contact the installing contractor or product manufacturer with any questions.

Some procedures in this section result in the operation of the associated alarms. Notify the owner and the fire department, central station, or other signal station to which the alarms are connected before performing the tests.

It is recommended that automatic sprinkler systems be inspected, tested, and maintained by a qualified Inspection Service in accordance with the NFPA and any applicable standards recognized by the Approval agency.

### Drop in Water Supply Pressure Below Normal Range

## NOTICE

If the water supply pressure is significantly reduced below the normally expected static pressure range (as could occur in the case of a water main break or repair), and there is a subsequent drop in the diaphragm chamber water pressure below its normal range (for example, due to a leak in a piping connection to or from the diaphragm chamber or, a leak in the diaphragm chamber check valve caused by dirt or debris in the check valve seal area), a deluge valve such as the DV-5A could inadvertently trip, if its water supply pressure is quickly restored.

A drop in the water supply pressure to below its normal range (as in the case of an interrupted water supply condition) constitutes an emergency impairment.

Should this condition occur, immediately close the System Main Control Valve (B) and use the following procedure to reset the system:

**Step 1.** Prior to the water supply pressure being restored to the closed System Main Control Valve (B), note the pressure indicated by the Diaphragm Gauge (K) and determine if the pressure is within the normally expected range.

**Step 2.** If the diaphragm chamber pressure is below the normal range, check for and correct any source of leakage from the diaphragm chamber prior to resetting the system.

**Step 3.** After the water supply pressure is restored to the System Main Control Valve (B), reset the DV-5A Valve in accordance with the Valve Setting Procedure section.

## NOTICE

For fire protection systems subject to an emergency impairment caused by an interrupted water supply condition, it is recommended that consideration be given to installing a low water supply pressure switch with the appropriate alarm/indications to monitor the water supply pressure.

### Waterflow Alarm Test Procedure

To test the waterflow alarm, open the Alarm Test Valve (G), which will allow a flow of water to the Waterflow Pressure Switch (C) and/or Water Motor Alarm. Upon satisfactory completion of the test, close the Alarm Test Valve (G).

To ensure drainage of the alarm line, depress the plunger on the Automatic Drain Valve (F).

### Supervisory Low Pressure Alarm Test Procedure

Proper operation of the Supervisory Low Pressure Switch (U) must be performed as follows:

**Step 1.** Open the System Drain Valve (E) just enough to slowly relieve supervisory air pressure from the system. Verify that the Supervisory Low Pressure Switch (U) is operational and that the low pressure set point is approximately 5 psi (0,34 bar).

**Step 2.** Close the System Drain Valve (E) and allow the system supervisory pressure of  $10 \pm 2$  psi (0,69  $\pm$  0,14 bar) to be automatically re-established. The Supervisory Low Pressure Switch (U) should return to its normal condition.

Pressure Relief Valve Maintenance Over pressurization of the system piping with air will result in the opening of the Supervisory Air Pressure Relief Valve (T). If the Supervisory Air Pressure Relief Valve (T) continues to bleed air after the system pressure has been reduced to its normal supervisory pressure range of  $10 \pm 2$  psi (0,69  $\pm$  0,14 bar), most likely debris became lodged in the seating area. To help clean the seating area, slowly pull up on the ring at the top of the Supervisory Air Pressure Relief Valve (T) to allow a full flow of air through the Supervisory Air Pressure Relief Valve (T), and then release the ring to allow the Supervisory Air Pressure Relief Valve (T) to snap closed. Repeat the cleaning procedure as necessary.

#### Electric Actuation Solenoid Valve Test Procedure

Proper operation of the Solenoid Valve (V) for electric actuation must be verified at as follows:

**Step 1.** Close the System Main Control Valve (B).

Step 2. Open the Main Drain Valve (D).

**Step 3.** Test the deluge releasing panel in accordance with the manufacturer's instructions to energize the solenoid valve.

**Step 4.** Verify that there is a flow of water from the Solenoid Valve drain connection.

**Step 5.** Verify that the Diaphragm Chamber pressure has decreased to below 25% of the water supply pressure.

## TFP1421 Page 15 of 18

**Step 6.** Reset the electric detection system in accordance with the manufacturer's instructions to de-energize the Solenoid Valve (V), and proceed as follows:

- Water should cease draining from the Solenoid Valve (V) but remain draining from the Manual Reset Actuator (N).
- Press the Reset Knob on the Manual Reset Actuator (N) and hold it a few seconds until water stops flowing from its drain tube.
- Pressure will then build up in the DV-5<sub>A</sub> Diaphragm Chamber.
- After system pressure is restored in the DV-5A Diaphragm Chamber, inspect the Solenoid Valve (U) and Manual Reset Actuator (N) for leaks at the drain tube. Any leaks must be corrected before proceeding to the next step.

**Step 7.** Partially open the System Main Control Valve (B). Slowly close the Main Drain Valve (D) as soon as water discharges from the Main Drain Valve (D). Observe the Automatic Drain Valve (F) for leaks. If there are leaks, determine/correct the cause of the leakage problem. If there are no leaks, the DV-5A Valve is ready to be placed in service and the System Main Control Valve (B) must then be fully opened.

#### **Internal Valve Inspection**

Once every five years during the annual operational test procedure and prior to the DV-5A Valve being reset and with the DV-5A Valve de-pressurized, the interior of the DV-5A Valve must be cleaned and inspected for wear and damage. Damaged or worn parts must be replaced. (Replacement of the Diaphragm every ten years is recommended, or more frequently if inspections and/or wear and tear warrant more frequent replacement.)

#### NOTICE

The Diaphragm Cover may be removed between Steps 4 and 5 of the resetting instructions, since at that point the DV-5<sub>A</sub> Valve should be de-pressurized as evident by a zero gauge reading on the Diaphragm Gauge (K) and Water Supply Gauge (J), as well as no water discharging from the Automatic Drain Valve (F). To perform internal valve inspection between Steps 4 and 5 of the Valve Setting Procedure remove the Diaphragm cover as follows:

**Step 1.** Close the Inverted Flare Shut-Off Valve (R).

**Step 2.** Remove the Copper Tube Fitting between the Diaphragm Supply Valve (P) and the Inverted Flare Shut-Off Valve (R).

**Step 3.** Loosen the union securing the Electric Actuation Trim and remove the Electric Actuation Trim.

**Step 4.** Loosen and remove the union between the Diaphragm Cover and the MRA-1 Manual Reset Actuator (N) and remove the MRA-1 Manual Reset Actuator (N) subassembly.

**Step 5.** Remove the Diaphragm Valve Cover hardware, then slowly remove the Diaphragm Cover and perform internal valve inspection. Clean the valve interior and replace parts as necessary.

After cleaning and inspecting valve interior, and replacing parts as necessary, reinstall the Diaphragm Cover by completing the following steps to assure the Diaphragm Cover Fasteners are uniformly and securely tightened.

**Step 1.** With reference to Figure 1, ensure that the Diaphragm is properly oriented and that the proper hardware arrangement is utilized when assembling the Diaphragm Covers. The hardware arrangements differ depending on the size of the DV-5A Valve.

**Step 2.** By first using the Long Hex Bolts, support of the Diaphragm Cover will be provided before installing the Short Hex Bolts. Align Diaphragm in proper orientation with Valve Body, and then align Diaphragm Cover in proper orientation with Valve Body. Handtighten all fasteners.

**Step 3.** Using crossdraw sequence to assure uniformity, wrench-tighten Long Hex Bolts and Short Hex Bolts to appropriate torque values. Repeat crossdraw sequence two to three times at incremental torque valves until reaching the torque valves found in Table B.

**Step 4.** Inspect to assure all Hex Bolts are securely tightened.

**Step 5.** Using the union, secure the MRA-1 Manual Reset Actuator (N) to the Diaphragm Cover.

**Step 6.** Using the union, secure the Electric Actuation Trim.

**Step 7.** Replace the Copper Tube Fitting between the Diaphragm Supply Valve (P) and the Inverted Flare Shut-Off Valve (R).

Nominal Valve Sizes	Torque lb-ft (N·m)					
ANSI Inches (DN)	Nuts	Short Hex Bolts				
1 1/2	44	35				
(40)	(59,7)	(47,5)				
2	44	35				
(50)	(59,7)	(47,5)				
3	125	125				
(80)	(169,5)	(169,5)				
4	150	150				
(100)	(203,4)	(203,4)				
6 <sup>1</sup>	150	150				
(150)	(203,4)	(203,4)				
8	188	188				
(200)	(254,9)	(254,9)				

NOTES

1. Also applicable to metric 165,1 mm size.

#### TABLE B DIAPHRAGM COVER BOLTS MINIMUM TORQUE

**Step 8.** Ensure that the unions and flare fittings are securely tightened.

**Step 9.** With the Diaphragm Supply Valve (P) closed, fully open the Inverted Flare Shut-Off Valve (R) stainless steel screw (approximately 1/2 in.) until resistance is met so as not to break the internal roll-pin. The internal roll-pin stops the removal of the Inverted Flare Shut-Off Valve (R) stainless steel screw.

**Step 10.** Proceed with Step 5 of the Valve Setting Procedures section in this data sheet.

#### NOTICE

If the water supply contains chemicals which tend to attack a polyester fabric-reinforced, EPDM rubber or the five year inspection indicates a build-up of debris within the DV-5A Valve that could affect its proper operation, then the frequency of the internal valve inspection procedure must be appropriately increased.

With reference to Figure 1, make certain that the Diaphragm is correctly oriented; otherwise, the DV-5A Valve cannot be properly set.

Under-tightening the Diaphragm Cover Bolts can result in internal and external leakage.

Use only TYCO replacement fasteners as specified in Figure 1.

Do not apply adhesives, lubricants, or other substances to the Diaphragm Valve Body.

# Limited Warranty

For warranty terms and conditions, visit www.tyco-fire.com.

## Ordering Procedure

The TYCO DV-5A Automatic Water Control Valves may be ordered as follows:

## **Pre-Assembled Valves** with Trim

## DV-5A Valves with Galvanized Trim and Butterfly Valve

Specify: Size (specify), DV-5A Automatic Water Control Valve, G x G connections with assembled galvanized Americas Single Interlock Preaction Electric Actuation Trim, complete with assembled Model BFV-300 Butterfly Valve, P/N (specify):

#### Groove x Groove

1 1/2 in. (DN40) 551011315
2 in. (DN50)
3 in. (DN80) 551011330
4 in. (DN100)
6 in. (DN150)
8 in. (DN200)

#### Notes:

AMERICAS DV-5A Valve with Trim and Butterfly Valve: Americas pressure switches, P/N52-287-1-124 solenoid valve, and psi/kPa water pressure gauges are provided.

This arrangement is available for EMEA and APAC upon request. Contact your local distributor.

### AMERICAS

#### **DV-5A Valves with Galvanized Trim**

Specify: Size (specify), DV-5A Automatic Water Control Valve, (specify) end connection with assembled galvanized Americas Single Interlock Preaction Electric Actuation Trim, P/N (specify):

### Groove x Groove

1 1/2 in. (DN40) 550011315	
2 in. (DN50)	
3 in. (DN80) 550011330	
4 in. (DN100)	
6 in. (DN150)	
8 in. (DN200)	

#### Flange x Flange ANSI

3 in. (DN80)	. 550021330
4 in. (DN100)	. 550021340
6 in. (DN150)	. 550021360
8 in (DN200)	550021380

#### Flange x Grove ANSI

3 in. (DN80)	. 550031330
4 in. (DN100)	. 550031340
6 in. (DN150)	.550031360
8 in. (DN200)	. 550031380

#### T x T NPT

Separate DV-5A Valves without Trim See Table A for flange drilling specifications.

Specify: Size (specify), DV-5A Automatic Water Control Valve, (specify) end connection, P/N (specify):

#### Groove x Groove

1 1/2 in. (DN40)
2 in. (DN50)
3 in. (DN80)
4 in. (DN100)
6 in. (DN150)530010060
8 in. (DN200)530010080

### Flange x Flange ANSI

3 in. (DN80)530020030	
4 in. (DN100)530020040	
6 in. (DN150)530020060	
8 in. (DN200)530020080	

#### Flange x Grove ANSI

3 in. (DN80)	
4 in. (DN100)	
6 in. (DN150)	
8 in. (DN200)	
T x T NPT	
1 1/2 in (DN/40)	530060015

1 1/2 in. (DN40) ......530060015 2 in. (DN50) .....530060020

#### Notes:

Valves are typically provided with flange drilling per ANSI B16.1 (Class 125) or ISO (7005-2 PN16).

Upon request, valves can be provided with flange drilling per JIS B 2210 or AS 2129. In which case part numbers are not assigned.

#### **DV-5**<sup>A</sup> Valve Trim

Specify: Size (specify), finish (specify), Electric Actuation Trim for DV-5A Automatic Water Control Valves used in Single Interlock Preaction Fire Protection System, P/N (specify):

#### Galvanized

1 1/2 in. (DN40)
2 in. (DN50)
3 in. (DN80)
4 in. (DN100)540001340
6 in. (DN150)540001360
8 in. (DN200)540001380
Black
1 1/2 in. (DN40)
2 in (DN50) 542001320

2 in. (DN50)
3 in. (DN80)
4 in. (DN100)542001340
6 in. (DN150)542001360
8 in. (DN200)

#### Note:

Pressure switches and/or solenoid valves for electric actuation are separately ordered.

### EMEA

#### **DV-5A Valves with Galvanized Trim**

Specify: Size (specify), DV-5A Automatic Water Control Valve, (specify) end connection with assembled galvanized EMEA Single Interlock Preaction Electric Actuation Trim, P/N (specify):

#### Groove x Groove

1 1/2 in. (DN40) 550111315
2 in. (DN50) 550111320
3 in. (DN80) 550111330
4 in. (DN100)
6 in. (DN150)
165,1 mm
8 in. (DN200) 550111380

#### Flange x Flange ANSI

3 in. (DN80)
4 in. (DN100)
6 in. (DN150)
8 in. (DN200) 550121380

#### Flange x Groove ANSI

3 in. (DN80)	550131330
4 in. (DN100)	550131340
6 in. (DN150)5	50131360
8 in. (DN200)5	550131380

#### Flange x Flange ISO

3 in. (DN80) 550141330
4 in. (DN100)
6 in. (DN150)
8 in. (DN200) 550141380

#### Flange x Groove ISO

3 in. (DN80)
6 in. (DN150)
8 in. (DN200) 550151380
<b>T x T ISO</b> 1 1/2 in. (DN40) 550171315

## 

#### Notes:

Pressure switches, P/N 52-287-1-124 solenoid valve, bar/psi water pressure gauges, and NPT to ISO threaded trim adaptors for external connections are provided.

## Separate DV-5A Valves without Trim

See Table A for flange drilling specifications.

Specify: Size (specify), DV-5A Automatic Water Control Valve, (specify) end connection, P/N (specify):

#### Groove x Groove

1 1/2 in. (DN40)
2 in. (DN50)
3 in. (DN80)530010030
4 in. (DN100)530010040
6 in. (DN150)530010060
165,1 mm
8 in. (DN200)530010080

#### Flange x Flange ANSI

3 in. (DN80)	 .530020030
4 in. (DN100)	 .530020040
6 in. (DN150)	 .530020060
8 in. (DN200)	 .530020080

#### Flange x Grove ANSI

3 in. (DN80)	 
4 in. (DN100)	 .530030040
6 in. (DN150)	 
8 in. (DN200) .	 

#### T x T NPT

1 1/2 in. (DN40)
2 in. (DN50)

#### Flange x Flange ISO 6 in. (DN150).....530040060 8 in. (DN200) .....530040080 Flange x Groove ISO 3 in. (DN80) ......530050030 6 in. (DN150).....530050060 8 in. (DN200) ......530050080 T x T ISO

TXTISO
1 1/2 in. (DN40)530070015
2 in. (DN50)530070020

#### Notes:

Valves are typically provided with flange drilling per ANSI B16.1 (Class 125) or ISO (7005-2 PN16).

Upon request, valves can be provided with flange drilling per JIS B 2210 or AS 2129. In which case part numbers are not assigned.

#### **DV-5**A Valve Trim

Specify: Size (specify), finish (specify), Electric Actuation Trim for DV-5A Automatic Water Control Valves used in Single Interlock Preaction Fire Protection System, P/N (specify):

#### Galvanized

1 1/2 in. (DN40) 540101320
2 in. (DN50)
3 in. (DN80)
4 in. (DN100)
6 in. (DN150)
8 in. (DN200)
Black

1 1/2 in. (DN40) 542101320	
2 in. (DN50) 542101320	
3 in. (DN80)	
4 in. (DN100)	
6 in. (DN150)	
8 in. (DN200)	

*Note: Pressure switches, solenoid valves* for electric actuation, water pressure gauges, and BFV-300 Butterfly Valve are separately ordered. NPT to ISO threaded adaptors are provided for External Trim Connections (drains, pressure switches, water motor alarms, etc.).

## APAC

### **DV-5A Valves with Galvanized Trim**

Specify: Size (specify), DV-5A Automatic Water Control Valve, (specify) end connection with assembled galvanized APAC Single Interlock Preaction Electric Actuation Trim, P/N (specify):

### Groove x Groove

1 1/2 in. (DN40) 550011315
2 in. (DN50) 550011320
3 in. (DN80)
4 in. (DN100)
6 in. (DN150)550011360
165,1 mm 550011366
8 in. (DN200) 550011380

#### Flange x Flange ANSI

3 in. (DN80)	60021330
4 in. (DN100)55	60021340
6 in. (DN150)55	60021360
8 in. (DN200)55	0021380

#### nge x Groove ANSI

Flange X Groove ANSI	
3 in. (DN80)	. 550031330
4 in. (DN100)	. 550031340
6 in. (DN150)	.550031360
8 in. (DN200)	. 550031380
T x T NPT	
1 1/2 in. (DN40)	. 550061315
2 in. (DN50)	
Flange x Flange ISO	
3 in. (DN80)	. 550041330
4 in. (DN100)	. 550041340
a. (B.L. Co)	FF0044000

3 III. (DINOU)	 . 000041000
4 in. (DN100)	 . 550041340
6 in. (DN150).	 . 550041360
8 in. (DN200)	 . 550041380

#### Flange x Groove ISO

3 in. (DN80)	51330
4 in. (DN100)	51340
6 in. (DN150)55008	51360
8 in. (DN200)5500	51380

Note: Pressure switches, P/N 52-287-1-124 solenoid valve, and psi/kPa water pressure gauges are provided.

Separate DV-5A Valves without Trim See Table A for flange drilling specifications.

Specify: Size (specify), DV-5A Automatic Water Control Valve, (specify) end connection, P/N (specify):

#### Groove x Groove

1 1/2 in. (DN40) 530010015
2 in. (DN50)
3 in. (DN80)
4 in. (DN100)
6 in. (DN150)530010060
165,1 mm
8 in. (DN200)

#### Flange x Flange ANSI

3 in. (DN80)	530020030
4 in. (DN100)	530020040
6 in. (DN150)	530020060
8 in. (DN200)	530020080

#### Flange x Grove ANSI

3 in. (DN80) 4 in. (DN100) 6 in. (DN150) 8 in. (DN200)	530030040 530030060
<b>T x T NPT</b> 1 1/2 in. (DN40)	
Flange x Flange ISO 3 in. (DN80) 4 in. (DN100)	530040040

Elenne y Greeve ISO	
8 in. (DN200)	530040080
6 in. (DN150)	530040060

#### T x T ISO

1 1/2 in. (DN40)			•		•	•	•		•		•	•		. 530070015
2 in. (DN50)		•	•	•	•	•	•	•	•	•	•	•	•	.530070020

#### Notes:

Valves are typically provided with flange drilling per ANSI B16.1 (Class 125) or ISO (7005-2 PN16).

Upon request, valves can be provided with flange drilling per JIS B 2210 or AS 2129. In which case part numbers are not assigned.

#### **DV-5**<sup>A</sup> Valve Trim

Specify: Size (specify), finish (specify), Electric Actuation Trim for DV-5A Automatic Water Control Valves used in Single Interlock Preaction Fire Protection System, P/N (specify):

#### Galvanized

1 1/2 in. (DN40)
2 in. (DN50)
3 in. (DN80)
4 in. (DN100)
6 in. (DN150)540001360
8 in. (DN200)540001380
Black
1 1/2 in. (DN40)
2 in. (DN50)
3 in. (DN80)
4 in. (DN100)

Note: Pressure switches and/or solenoid valves for electric actuation are separately ordered.

6 in. (DN150).....542001360

8 in. (DN200) ......542001380

## **DV-5A Valve Trim Accessories**

(for separately ordered valve trim) Specify: Specify Accessory Description), P/N (specify):

Waterflow Pressure Alarm Switch, Potter PS10-2 (America/APAC)
PS10-1 (EMEA)0260 Supervisory Air Pressure Alarm Switch, Potter PS40-2 (America/APAC)25710
Supervisory Air Pressure Alarm Switch PS40-1 (EMEA)0262 Model WMA-1 Water Motor Alarm
(America/APAC)526301001P Model WMA-1 Water Motor Alarm
(EMEA)
Air Supply
Supervisory Air Supply
Supervisory Air Supply523282001 Water Gauges
with bar/psi025500013 600 psi Water Gauge psi/kPa
(service pressure over 300 psi) 923431004 Solenoid Valve for
Releasing Service Refer to Technical
Data Sheet TFP2180

#### **DV-5A Valve Replacement Parts**

Specify: (Description) for use with (specify size) DV-5A Automatic Water Control Valve, P/N (See Figure 1)

#### **DV-5**<sub>A</sub> Valve Trim Replacement Parts

Specify: (Description) for use with DV-5A Valve Trim, P/N (See Figure 6)

**TFP1421** Page 18 of 18

1400 Pennbrook Parkway, Lansdale, PA 19446 | Telephone +1-215-362-0700

© 2022 Johnson Controls. All rights reserved. All specifications and other information shown were current as of document revision date and are subject to change without notice.

